



SCI/NHBC Certification

Rollalong Ltd

HDA - Modular Steel Frame System

SCI / NHBC Stage 1 System Certification

The Steel Construction Institute has assessed the structural aspects of the Rollalong HDA modular steel frame system for Stage 1 – System Certification and confirms that it is suitable for use in the construction of dwellings in accordance with NHBC Standards Chapter 6.10 “Light steel framed walls and floors”.

The system has been assessed for residential buildings up to 5 storeys high. As its basic components the system uses cold rolled galvanised C-sections for wall studs and floor joists designed in accordance with BS EN 1993-1-3.

To confirm validity, please visit the SCI Certification and Assessment website at www.sci-assessed.com.



Product ID: 20290409
End Date: 9th April 2029

Dr Graham Couchman, Chief Executive
The Steel Construction Institute